

Asbestos Inspection Report

516 James Street
Florence, South Carolina


Prepared for: City of Florence

324 W. Evans Street

Florence, SC 29501

Annie Brown ahbrown@cityofflorence.com

Prepared by: Enga Hair, AHERA Building Inspector License #BI-01591



Date of Inspection: February 20, 2026

Date of Report: February 25, 2026

Project Number: 26-807

ECH CONSULTANTS

1823 Trade Street
Florence, SC
803.807.6488

February 25, 2026

Dr. Annie Brown, Ph.D
City of Florence
324 W. Evans Street
Florence, SC 29501

RE: 516 James Street
Florence, SC

Dear Dr. Brown,

We are pleased submit the enclosed limited Asbestos Inspection Report for the above captioned project. The inspection was conducted on February 20, 2026, in conformance with the South Carolina Department Environmental Services (SCDES) Standards of Performance for Asbestos Projects, Regulation 61-86.1 and the Environmental Protection Agency (EPA) minimum sampling requirements.

If you have any questions or need any additional information please do not hesitate to call me at 803.807.6488 or email me at enga@echconsultants.com.

Respectfully,


Enga Hair, CIH, PE




TABLE OF CONTENTS

| | |
|-------------------------------|---|
| EXECUTIVE SUMMARY | 3 |
| BACKGROUND | 4 |
| ASBESTOS FINDINGS | 5 |
| ASBESTOS CONCLUSIONS | 6 |
| PHOTOGRAPHS | 7 |
| ASBESTOS BULK SAMPLE ANALYSIS | |
| SCDES INSPECTOR LICENSE | |

EXECUTIVE SUMMARY

The purpose of this investigation was to conduct a visual inspection, sample and analyze suspect asbestos containing materials (ACM) which may be disturbed during the future **demolition**, to determine if any occupational exposures and/or environmental releases of airborne asbestos may occur.

The suspect materials were those identified in the United States Environmental Protection Agency (EPA) manual, Guidance for Controlling Asbestos. The identification of ACM meet compliance standards established the EPA under regulation 40 CFR, Part 61, National Emission Standards for Hazardous Air Pollutants, Asbestos NESHAP Revision, Final Rule. Additional suspect ACMs may be present in locations that are inaccessible. If discovered, these suspect materials should be sampled and tested. A material that is of similar color, texture, age and size throughout the building to a material that has been identified as asbestos containing should be assumed to contain asbestos.

The survey was conducted by licensed inspector Enga Hair - #01591 on December 23, 2025. Bulk samples were recorded on a Chain of Custody and submitted to a Polarized Light Microscopy (PLM) laboratory. Eurofins|CEI Labs, Inc., located in Cary, North Carolina, is accredited by the National Voluntary Laboratory Accreditation Program (NVLAP) for satisfactory compliance with criteria established in Title 15, part 7, Code of Regulations, by the National Institute of Standards and Technology (NIST). The laboratory analysis reports the specific type of asbestos identified (there are six (6) types of asbestos minerals) and the percentage of asbestos present.

The EPA defines materials as asbestos containing IF an asbestos content of greater than 1% is detected in a representative sample. The sampling strategy utilized throughout the survey complies with the instructions specified in the EPA Regulation 40 CFR, Part 763.

ECH Consultants appreciates the opportunity to provide this limited asbestos inspection report for use by City of Florence and their assigns.

BACKGROUND

The structure located at 516 James Street, Florence, South Carolina, is scheduled for a future demolition. The facility has the following characteristics:

- Single story wooden structure
- Approximately 800 Square Feet
- Approximately 800 Square Feet of Shingles
- Approximately 850 Square Feet of Ceiling Tile
- Wood floors and walls throughout
- Painted wooden ceiling throughout
- Approximately 150 Square Feet of Drywall with no Joint Compound on ceiling in kitchen and hallway
- Approximately 100 Square Feet of Cream VFC#1
- Approximately 100 Square Feet of Cream/Blue VFC#2

ASBESTOS FINDINGS

The following Table details the twelve (12) Bulk Samples taken

| Sample # | Description | Classification | Condition | Potential for Disturbance |
|----------|------------------------|----------------|-----------|---------------------------|
| 1 | Drywall | None Detected | Damaged | Low |
| 2 | Drywall | None Detected | Damaged | Low |
| 3 | Drywall | None Detected | Damaged | Low |
| 4 | Cream Sheet Vinyl | None Detected | Damaged | Low |
| 5 | Cream Sheet Vinyl | None Detected | Damaged | Low |
| 6 | Cream Sheet Vinyl | None Detected | Good | Low |
| 7 | Cream/Blue Sheet Vinyl | None Detected | Good | Low |
| 8 | Cream/Blue Sheet Vinyl | None Detected | Good | Low |
| 9 | Cream/Blue Sheet Vinyl | None Detected | Good | Low |
| 10 | Shingle | None Detected | Good | Low |
| 11 | Shingle | None Detected | Good | Low |
| 12 | Shingle | None Detected | Good | Low |

Please refer to the enclosed Asbestos Analysis for additional information

ASBESTOS CONCLUSIONS

The following represents areas that are POSITIVE for Asbestos:

Non-Friable: N/A

Friable: N/A

*No Asbestos Containing Materials identified in this inspection

PHOTOGRAPHS



PHOTOGRAPH 1



PHOTOGRAPH 2



PHOTOGRAPH 3

ASBESTOS BULK SAMPLE ANALYSIS



Bulk Building Material Testing

February 24, 2026

Enga Hair
ECH Consultants
1823 Trade Street
Florence, SC 29501

CLIENT PROJECT: Florence , 516 James St
LAB CODE: 727384-1

Dear Enga,

Enclosed are asbestos analysis results for PLM Bulk samples received at our laboratory on 02/23/26. The samples were analyzed for asbestos using polarizing light microscopy (PLM) per the EPA 600/R-93/116: Method for the Determination of Asbestos in Bulk Building Materials and EPA 40 CFR Appendix E to Subpart E of Part 763: Interim Method of the Determination of Asbestos in Bulk Insulation Samples.

Sample results containing >1% asbestos are considered asbestos-containing materials (ACMs) per EPA regulatory requirements. The detection limit for the EPA 600 Method is <1% by calibrated visual estimate.

Thank you for your business and we look forward to continuing good relations.

Kind Regards,

Kamila Reichert,
Laboratory Director

NVLAP 600323-0



Built Environment Testing

ASBESTOS ANALYTICAL REPORT
By: Polarized Light Microscopy

Prepared for

ECH Consultants

| | |
|-------------------------|--|
| CLIENT PROJECT: | Florence , 516 James St |
| LAB CODE: | 727384-1 |
| TEST METHOD: | EPA 600 / R93 / 116 and EPA 40 CFR Appendix E to Subpart E of Part 763 |
| REPORT DATE: | 02/24/26 |
| TOTAL SAMPLES ANALYZED: | 9 |
| # SAMPLES >1% ASBESTOS: | 0 |
| TOTAL LAYERS ANALYZED: | 9 |



100% Environmental Testing

Asbestos Report Summary By: Polarized Light Microscopy

Project: Florence , 516 James St

Lab Code: 727384-1

Method: EPA 600 / R93 / 116 and EPA 40 CFR Appendix E to Subpart E of Part 763

| Client ID | Lab ID | Layer | Sample Description | Asbestos % |
|-----------|---------|-------|-----------------------------------|---------------|
| 1 | 4156689 | | White drywall | None Detected |
| 2 | 4156690 | | White drywall | None Detected |
| 3 | 4156691 | | White drywall | None Detected |
| 4 | 4156692 | | Cream sheet vinyl | None Detected |
| 5 | 4156693 | | Cream sheet vinyl | None Detected |
| 6 | 4156694 | | Sample Submitted for TEM Analysis | |
| 7 | 4156695 | | Cream/blue sheet vinyl | None Detected |
| 8 | 4156696 | | Cream/blue sheet vinyl | None Detected |
| 9 | 4156697 | | Sample Submitted for TEM Analysis | |
| 10 | 4156698 | | Black shingle | None Detected |
| 11 | 4156699 | | Black shingle | None Detected |
| 12 | 4156700 | | Sample Submitted for TEM Analysis | |



Real Time Environmental Testing

ASBESTOS BULK ANALYSIS

By: Polarized Light Microscopy

Client: ECH Consultants
1823 Trade Street
Florence, SC 29501

Lab Code: 727384-1
Date Received: 02/23/26
Date Analyzed: 02/23/26
Date Reported: 02/24/26

Project: Florence , 516 James St

Method: ASBESTOS BULK PLM, EPA 600 METHOD

| Client ID Lab ID | Lab Description | Lab Attributes | NON-ASBESTOS COMPONENTS | | | ASBESTOS % |
|---------------------|-----------------------------------|---|-------------------------|----------------------------------|-----------------|---------------|
| | | | Fibrous | Non-Fibrous | | |
| 1 4156689 | Drywall | Heterogeneous White Fibrous Bound | 20% | Cellulose 80% | Gypsum | None Detected |
| 2 4156690 | Drywall | Heterogeneous White Fibrous Bound | 20% | Cellulose 80% | Gypsum | None Detected |
| 3 4156691 | Drywall | Heterogeneous White Fibrous Bound | 20% | Cellulose 80% | Gypsum | None Detected |
| 4 4156692 | Sheet Vinyl | Heterogeneous Cream Fibrous Bound | 20% 10% | Cellulose Glass 50% 20% | Vinyl Binder | None Detected |
| 5 4156693 | Sheet Vinyl | Heterogeneous Cream Fibrous Bound | 20% 10% | Cellulose Glass 50% 20% | Vinyl Binder | None Detected |
| 6 4156694 | Sample Submitted for TEM Analysis | | | | | |
| 7 4156695 | Sheet Vinyl | Heterogeneous Cream/blue Fibrous Bound | 20% 10% | Cellulose Glass 50% 20% | Vinyl Binder | None Detected |
| 8 4156696 | Sheet Vinyl | Heterogeneous Cream/blue Fibrous Bound | 20% 10% | Cellulose Glass 50% 20% | Vinyl Binder | None Detected |



Bulk Air, Surface, Testing

ASBESTOS BULK ANALYSIS

By: Polarized Light Microscopy

Client: ECH Consultants
1823 Trade Street
Florence, SC 29501

Lab Code: 727384-1
Date Received: 02/23/26
Date Analyzed: 02/23/26
Date Reported: 02/24/26

Project: Florence , 516 James St

Method: ASBESTOS BULK PLM, EPA 600 METHOD

| Client ID | Lab | Lab | NON-ASBESTOS COMPONENTS | | | | ASBESTOS |
|---------------|-------------|--|-------------------------|-------|-------------|---------------|---------------|
| Lab ID | Description | Attributes | Fibrous | | Non-Fibrous | | % |
| 9 4156697 | | Sample Submitted for TEM Analysis | | | | | |
| 10 4156698 | Shingle | Heterogeneous Black Fibrous Bound | 50% | Glass | 40% | Tar Gravel | None Detected |
| 11 4156699 | Shingle | Heterogeneous Black Fibrous Bound | 50% | Glass | 40% | Tar Gravel | None Detected |
| 12 4156700 | | Sample Submitted for TEM Analysis | | | | | |



LEGEND:

- Non-Anth = Non-Asbestiform Anthophyllite
 - Non-Trem = Non-Asbestiform Tremolite
 - Calc Carb = Calcium Carbonate
-

METHOD: EPA 600 / R93 / 116 and EPA 40 CFR Appendix E to Subpart E of Part 763

REPORTING LIMIT: 1% by calibrated visual estimation

REGULATORY LIMIT: 1%

Due to the limitations of the EPA 600 / R93 / 116 method, nonfriable organically bound materials (NOBs) such as vinyl floor tiles can be difficult to analyze via polarized light microscopy (PLM). EPA recommends that all NOBs analyzed by PLM, and found not to contain asbestos, be further analyzed by Transmission Electron Microscopy (TEM). Please note that PLM analysis of dust and soil samples for asbestos is not covered under NVLAP accreditation. Estimated measurement of uncertainty is available on request.

Eurofins Built Environment Testing East, LLC makes no warranty representation regarding the accuracy of client submitted information in preparing and presenting analytical results. Interpretation of the analytical results is the sole responsibility of the client. This report relates only to the samples tested or analyzed and may not be reproduced, except in full, without written approval by Eurofins Built Environment Testing East, LLC. Samples were received in acceptable condition unless otherwise noted. This report may not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. Government.

Information provided by customer includes customer sample ID and sample description.


Olivia Gardner
Analyst

DATA QA:

Madelyn Schmidt
2/24/2026

APPROVED BY:

Kamila Reichert,
Laboratory Director



CHAIN OF CUSTODY

1000 PLYMOUTH ROAD, SUITE 1000, WILMINGTON, DE 19804
 TEL: 302.526.9141 FAX: 302.441.1444

ECEI Lab Code: 1000000000

ECEI Lab ID Range: 1000000000

| COMPANY INFORMATION | | PROJECT INFORMATION | |
|---------------------|--|------------------------|--|
| ECEI CLIENT # | | Job Contact | |
| Company | | Email To | |
| Address | | Project Name | |
| | | Project CIB | |
| Building | | Job # | |
| City | | Point of sample origin | |

IF TAT IS NOT MARKED STANDARD 3 DAY TAT APPLIES.

| ASBESTOS | METHOD | TURN AROUND TIME | | | | | |
|------------------------|-------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| | | 4 HR | 8 HR | 1 DAY | 2 DAY | 3 DAY | 6 DAY |
| PLM Bulk | EPA 8000-2-0115 | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| PLM Point Count | EPA 8000-2-0115 | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| PLM Gravimetric | EPA 8000-2-0115 | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| PLM Grav + Point Count | EPA 8000-2-0115 | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| PLM Bulk | 2400.40 | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| PLM Air | NIOSH 1400 | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| PLM Air | EPA 8000-2-0115 | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| PLM Air | NIOSH 1400 | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| PLM Air (HVE) | 2400.40 | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| PLM Air | ASTM 2297-15 | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| PLM Bulk | 2400.40 | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| PLM Soil | ASTM 1527-15 | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| PLM Environmental | INDICATIVE METHOD | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| PLM Qualitative | INDICATIVE METHOD | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| OTHER | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

Work should be taken from the same sample lot as listed on contract

REMARKS / SPECIAL INSTRUCTIONS

None

Access Samples
 Read Samples

| Relinquished By: | Date/Time | Received By | Date/Time |
|------------------|-----------|-------------|-----------|
| | | | |

By submitting samples you are agreeing to ECEI's Terms and Conditions
 Samples will be disposed of 30 days after analysis



0101.01 - Analytical Results

February 25, 2026

Enga Hair
ECH Consultants
1823 Trade Street
Florence, SC 29501

CLIENT PROJECT: Florence , 516 James St
LAB CODE: 727384-2

Dear Enga,

Enclosed are asbestos analysis results for TEM bulk samples received at our laboratory on 02/23/26. The samples were analyzed for asbestos using transmission electron microscopy (TEM) per Chatfield/EPA 600/R-93/116 Sec. 2.5.5.1 method.

Sample results containing > 1% asbestos are considered asbestos-containing materials (ACMs) per the EPA regulatory requirements. The detection limit for the TEM Chatfield/EPA 600/R-93/116 Sec. 2.5.5.1 method is <1% depending on the processed weight and constituents of the sample.

Thank you for your business and we look forward to continuing good relations.

Kind Regards,

Kamila Reichert,
Laboratory Director

NVLAP 600323-0



Bulk Environmental Testing

ASBESTOS ANALYTICAL REPORT
By: Transmission Electron Microscopy

Prepared for

ECH Consultants

| | |
|-----------------|---|
| CLIENT PROJECT: | Florence , 516 James St |
| LAB CODE: | 727384-2 |
| TEST METHOD: | Bulk Chatfield EPA 600 / R93 / 116 Sec. 2.5.5.1 |
| REPORT DATE: | 02/25/26 |



Soil and Environmental Testing

ASBESTOS BULK ANALYSIS

By: Transmission Electron Microscopy

Client: ECH Consultants
1823 Trade Street
Florence, SC 29501

Lab Code: 727384-2
Date Received: 02/23/26
Date Analyzed: 02/25/26
Date Reported: 02/25/26

Project: Florence , 516 James St

Method: TEM BULK CHATFIELD / EPA 600 / R93 / 116 Sec. 2.5.5.1

| Client ID Lab ID | Material Description | Sample Weight (g) | Organic Material (%) | Acid Soluble Material (%) | Acid Insoluble Material (%) | ASBESTOS % |
|---------------------|-------------------------|----------------------|-------------------------|------------------------------|--------------------------------|---------------|
| 6 4160254 | Cream sheet vinyl | 0.09 | 90.56 | 3.29 | 6.15 | None Detected |
| 9 4160255 | Cream/blue sheet vinyl | 0.07 | 87.1 | 0.72 | 12.17 | None Detected |
| 12 4160256 | Black shingle | 0.28 | 25 | 48.14 | 26.86 | None Detected |



Built Environment Testing

LEGEND: None

METHOD: Bulk Chatfield EPA 600 / R93 / 116 Sec. 2.5.5.1

LIMIT OF DETECTION: Varies with the weight and constituents of the sample (<1%)

REGULATORY LIMIT: 1%

Eurofins Built Environment Testing East, LLC makes no warranty representation regarding the accuracy of client submitted information in preparing and presenting analytical results. Interpretation of the analytical results is the sole responsibility of the client. This report relates only to the samples tested or analyzed and may not be reproduced, except in full, without written approval by Eurofins Built Environment Testing East, LLC.. Estimated measurement of uncertainty is available on request. Samples were received in acceptable condition unless otherwise noted.

Information provided by customer includes customer sample ID, location, volume and area as well as date and time of sampling. Eurofins Built Environment Testing East, LLC recommends between 0.500 and 0.200 grams of sample material. Any weight below 0.100 grams is considered below protocol guidelines.


Raegan Brown
Analyst

DATA QA:

Olivia Gardner
2/25/2026

APPROVED BY:

Kamila Reichert,
Laboratory Director



Built Environment Testing

RES Job #: 727384

Effective

| | | | |
|--|----------------------------|--|-------------------------|
| SUBMITTED BY | | INVOICE TO | |
| Company: ECH Consultants | Company: ECH Consultants | Contact: Enga Hair | SERIES: -1 PLM Priority |
| Address: 1823 Trade Street | Address: 1823 Trade Street | Phone: (803) 807-6488 | |
| Florence, SC 29501 | Florence, SC 29501 | Fax: | |
| Project Number and/or P.O. #: Florence | Project Zip Code: | Cell: (803) 807-6488 | |
| Project Description/Location: 516 James St | | Final Data Deliverable Email Address: enga@echconsultants.com (+ 1 ADDNL CONTACTS) | |

| ASBESTOS LABORATORY | REQUESTED ANALYSIS | | | | | | | VALID MATRIX CODES | | | | LAB NOTES | |
|---|-----------------------|----------|----------|----------|----------|--------|-----------|--------------------|---------|------|-----|---|------------------|
| | PLM / PCM / TEM / NYS | DTL | RUSH | PRIORITY | STANDARD | METALS | CHEMISTRY | VIABLES | MEDICAL | MOLD | ICO | | Air = A |
| Dust | RUSH | PRIORITY | STANDARD | | | | | | | | | Dust = D | Food = F |
| Metals | RUSH | PRIORITY | STANDARD | | | | | | | | | Paint = P | Soil = S |
| Organics* | SAME DAY | RUSH | PRIORITY | STANDARD | | | | | | | | Surface = SU | Swab = SW |
| MICROBIOLOGY LABORATORY | PRIORITY | STANDARD | | | | | | | | | | Tape = T | Wipe = W |
| Viabile Analysis** | RUSH | STANDARD | | | | | | | | | | Drinking Water = DW | Waste Water = WW |
| Medical Device Analysis | RUSH | STANDARD | | | | | | | | | | **ASTM E1792 approved wipe media only** | |
| Mold Analysis | RUSH | PRIORITY | STANDARD | | | | | | | | | | |
| **Turnaround times establish a laboratory priority, subject to laboratory volume and are not guaranteed. Additional fees apply for afterhours, weekends and holidays.** | | | | | | | | | | | | | |
| Special Instructions: SC samples, SC 1 day TEM, Stop positives; Combine to make weight for TEM if needed | | | | | | | | | | | | | |
| Client Sample ID Number (Sample ID's must be unique) | | | | | | | | | | | | | |
| 1 | X | | | | | | | | | | | | |
| 2 | X | | | | | | | | | | | | |
| 3 | X | | | | | | | | | | | | |
| 4 | X | | | | | | | | | | | | |
| 5 | X | | | | | | | | | | | | |
| 6 | X | | | | | | | | | | | | |
| 7 | X | | | | | | | | | | | | |
| 8 | X | | | | | | | | | | | | |
| 9 | X | | | | | | | | | | | | |
| 10 | X | | | | | | | | | | | | |
| 11 | X | | | | | | | | | | | | |
| 12 | X | | | | | | | | | | | | |

Eurofins Built Environment Testing East, LLC establishes a unique Lab Sample ID for each sample by preceding each unique Client Sample ID with the laboratory RES Job Number. Eurofins Built Environment Testing East, LLC will analyze incoming samples based on information received and will not be responsible for errors or omissions in calculations resulting from the inaccuracy of original data. By signing, client/company representative agrees that submission of the following samples for requested analysis as indicated on this Chain of Custody shall constitute an analytical services agreement with payment terms of NET30. Failure to comply with payment terms may result in a 18% APR finance charge.

Relinquished By: *Candice Wilkins* Date/Time: 02/23/2026 9:36:21 Sample Condition: Acceptable

Received By: Candice Wilkins Date/Time: 02/23/2026 11:10:07 Carrier: Fed-Ex

730 SE Maynard Rd, Cary, NC 27511
Page 1 of 1
https://www.eurofins.com/builtenv

SCDES INSPECTOR LICENSE



Enga Hair



| | | Expiration Date: |
|------------|----------|------------------|
| AIRSAMPLER | AS-00538 | 09/21/26 |
| CONSULTBI | BI-01591 | 09/22/26 |
| CONSULTPD | PD-00184 | 03/04/26 |
| SUPERAHERA | SA-02878 | 09/21/26 |