

Asbestos Inspection Report

556 Lawson Street
Florence, South Carolina

Prepared for: City of Florence

324 W. Evans Street

Florence, SC 29501

Annie Brown ahbrown@cityofflorence.com

Prepared by: Enga Hair, AHERA Building Inspector License #BI-01591 *Enga Hair*

Date of Inspection: April 12, 2026

Date of Report: April 16, 2026

Project Number: 26-832

ECH CONSULTANTS

1823 Trade Street
Florence, SC
803.807.6488

April 16, 2026

Dr. Annie Brown, Ph.D
City of Florence
324 W. Evans Street
Florence, SC 29501

RE: 556 Lawson Street
Florence, SC

Dear Dr. Brown,

We are pleased submit the enclosed limited Asbestos Inspection Report for the above captioned project. The inspection was conducted on April 12, 2026, in conformance with the South Carolina Department Environmental Services (SCDES) Standards of Performance for Asbestos Projects, Regulation 61-86.1 and the Environmental Protection Agency (EPA) minimum sampling requirements.

If you have any questions or need any additional information please do not hesitate to call me at 803.807.6488 or email me at enga@echconsultants.com.

Respectfully,


Enga Hair, CIH, PE

TABLE OF CONTENTS

EXECUTIVE SUMMARY	3
BACKGROUND	4
ASBESTOS FINDINGS	5
ASBESTOS CONCLUSIONS	6
PHOTOGRAPHS	7
ASBESTOS BULK SAMPLE ANALYSIS	
SCDES INSPECTOR LICENSE	

EXECUTIVE SUMMARY

The purpose of this investigation was to conduct a visual inspection, sample and analyze suspect asbestos containing materials (ACM) which may be disturbed during the future **demolition**, to determine if any occupational exposures and/or environmental releases of airborne asbestos may occur.

The suspect materials were those identified in the United States Environmental Protection Agency (EPA) manual, Guidance for Controlling Asbestos. The identification of ACM meet compliance standards established the EPA under regulation 40 CFR, Part 61, National Emission Standards for Hazardous Air Pollutants, Asbestos NESHAP Revision, Final Rule. Additional suspect ACMs may be present in locations that are inaccessible. If discovered, these suspect materials should be sampled and tested. A material that is of similar color, texture, age and size throughout the building to a material that has been identified as asbestos containing should be assumed to contain asbestos.

The survey was conducted by licensed inspector Enga Hair - #01591 on April 12, 2026. Bulk samples were recorded on a Chain of Custody and submitted to a Polarized Light Microscopy (PLM) laboratory. Eurofins|CEI Labs, Inc., located in Fort Mill, South Carolina, is accredited by the National Voluntary Laboratory Accreditation Program (NVLAP) for satisfactory compliance with criteria established in Title 15, part 7, Code of Regulations, by the National Institute of Standards and Technology (NIST). The laboratory analysis reports the specific type of asbestos identified (there are six (6) types of asbestos minerals) and the percentage of asbestos present.

The EPA defines materials as asbestos containing IF an asbestos content of greater than 1% is detected in a representative sample. The sampling strategy utilized throughout the survey complies with the instructions specified in the EPA Regulation 40 CFR, Part 763.

ECH Consultants appreciates the opportunity to provide this limited asbestos inspection report for use by City of Florence and their assigns.

BACKGROUND

The structure located at 556 Lawson Street, Florence, South Carolina, is scheduled for a future demolition. The facility has the following characteristics:

Single story wooden structure
Approximately 800 Square Feet
Approximately 800 Square Feet of Shingles
Approximately 600 Square Feet of Drywall with Joint Compound throughout kitchen
Wooden floors, walls and ceiling throughout
Wooden windows with Approximately 120 LF of window glaze

ASBESTOS FINDINGS

The following Table details the twelve (12) Bulk Samples taken

Sample #	Description	Classification	Condition	Potential for Disturbance
1	Drywall	None Detected	Damaged	Low
2	Drywall	None Detected	Damaged	Low
3	Drywall	None Detected	Damaged	Low
4	Joint Compound	None Detected	Damaged	Low
5	Joint Compound	None Detected	Damaged	Low
6	Joint Compound	None Detected	Damaged	Low
7	Glazing	None Detected	Good	Low
8	Glazing	None Detected	Good	Low
9	Glazing	None Detected	Good	Low
10	Shingle	None Detected	Good	Low
11	Shingle	None Detected	Good	Low
12	Shingle	None Detected	Good	Low

Please refer to the enclosed Asbestos Analysis for additional information

ASBESTOS CONCLUSIONS

The following represents areas that are POSITIVE for Asbestos:

Non-Friable: N/A


Friable: N/A

*No Asbestos Containing Materials identified in this inspection

PHOTOGRAPHS



PHOTOGRAPH 1



PHOTOGRAPH 2



PHOTOGRAPH 3

ASBESTOS BULK SAMPLE ANALYSIS



Built Environment Testing

April 15, 2026

Enga Hair
ECH Consultants
1823 Trade Street
Florence, SC 29501

CLIENT PROJECT: Florence , 556 Lawson St
LAB CODE: 741666-1

Dear Enga,

Enclosed are asbestos analysis results for PLM Bulk samples received at our laboratory on 04/14/26. The samples were analyzed for asbestos using polarizing light microscopy (PLM) per the EPA 600/R-93/116: Method for the Determination of Asbestos in Bulk Building Materials and EPA 40 CFR Appendix E to Subpart E of Part 763: Interim Method of the Determination of Asbestos in Bulk Insulation Samples.

Sample results containing >1% asbestos are considered asbestos-containing materials (ACMs) per EPA regulatory requirements. The detection limit for the EPA 600 Method is <1% by calibrated visual estimate.

Thank you for your business and we look forward to continuing good relations.

Kind Regards,

A handwritten signature in black ink that reads "Kamila Reichert".

Kamila Reichert,
Laboratory Director

NVLAP 600323-0



Built Environment Testing

ASBESTOS ANALYTICAL REPORT
By: Polarized Light Microscopy

Prepared for

ECH Consultants

CLIENT PROJECT:	Florence , 556 Lawson St
LAB CODE:	741666-1
TEST METHOD:	EPA 600 / R93 / 116 and EPA 40 CFR Appendix E to Subpart E of Part 763
REPORT DATE:	04/15/26
TOTAL SAMPLES ANALYZED:	10
# SAMPLES >1% ASBESTOS:	0
TOTAL LAYERS ANALYZED:	10



Built Environment Testing

Asbestos Report Summary By: Polarized Light Microscopy

Project: Florence , 556 Lawson St

Lab Code: 741666-1

Method: EPA 600 / R93 / 116 and EPA 40 CFR Appendix E to Subpart E of Part 763

Client ID	Lab ID	Layer	Sample Description	Asbestos %
1	4328805		White/tan drywall	None Detected
2	4328806		White/tan drywall	None Detected
3	4328807		White/tan drywall	None Detected
4	4328808		White joint compound	None Detected
5	4328809		White joint compound	None Detected
6	4328810		White joint compound	None Detected
7	4328811		White glazing	None Detected
8	4328812		White glazing	None Detected
9	4328813		Sample Submitted for TEM Analysis	
10	4328814		Black shingle	None Detected
11	4328815		Black shingle	None Detected
12	4328816		Sample Submitted for TEM Analysis	



Built Environment Testing

ASBESTOS BULK ANALYSIS

By: Polarized Light Microscopy

Client: ECH Consultants
1823 Trade Street
Florence, SC 29501

Lab Code: 741666-1
Date Received: 04/14/26
Date Analyzed: 04/15/26
Date Reported: 04/15/26

Project: Florence , 556 Lawson St

Method: ASBESTOS BULK PLM, EPA 600 METHOD

Client ID Lab ID	Lab Description	Lab Attributes	NON-ASBESTOS COMPONENTS			ASBESTOS %	
			Fibrous	Non-Fibrous			
1 4328805	Drywall	Heterogeneous White/tan Fibrous Bound	20%	Cellulose	80%	Gypsum	None Detected
2 4328806	Drywall	Heterogeneous White/tan Fibrous Bound	20%	Cellulose	80%	Gypsum	None Detected
3 4328807	Drywall	Heterogeneous White/tan Fibrous Bound	20%	Cellulose	80%	Gypsum	None Detected
4 4328808	Joint Compound	Heterogeneous White Non-Fibrous Bound			60%	Binder	None Detected
					35%	Calc Carb	
					5%	Paint	
5 4328809	Joint Compound	Heterogeneous White Non-Fibrous Bound			60%	Binder	None Detected
					35%	Calc Carb	
					5%	Paint	
6 4328810	Joint Compound	Heterogeneous White Non-Fibrous Bound			60%	Binder	None Detected
					35%	Calc Carb	
					5%	Paint	
7 4328811	Glazing	Homogeneous White Non-Fibrous Bound			85%	Binder	None Detected
					15%	Calc Carb	



Built Environment Testing

ASBESTOS BULK ANALYSIS

By: Polarized Light Microscopy

Client: ECH Consultants
1823 Trade Street
Florence, SC 29501

Lab Code: 741666-1
Date Received: 04/14/26
Date Analyzed: 04/15/26
Date Reported: 04/15/26

Project: Florence , 556 Lawson St

Method: ASBESTOS BULK PLM, EPA 600 METHOD

Client ID Lab ID	Lab Description	Lab Attributes	NON-ASBESTOS COMPONENTS			ASBESTOS %
			Fibrous	Non-Fibrous		
8 4328812	Glazing	Homogeneous White Non-Fibrous Bound	85% 15%	Binder Calc Carb	None Detected	
9 4328813		Sample Submitted for TEM Analysis				
10 4328814	Shingle	Heterogeneous Black Fibrous Bound	50%	Glass 40% 10%	Tar Gravel	None Detected
11 4328815	Shingle	Heterogeneous Black Fibrous Bound	50%	Glass 40% 10%	Tar Gravel	None Detected
12 4328816		Sample Submitted for TEM Analysis				



LEGEND:

- Non-Anth = Non-Asbestiform Anthophyllite
- Non-Trem = Non-Asbestiform Tremolite
- Calc Carb = Calcium Carbonate

METHOD: EPA 600 / R93 / 116 and EPA 40 CFR Appendix E to Subpart E of Part 763

REPORTING LIMIT: 1% by calibrated visual estimation

REGULATORY LIMIT: 1%

Due to the limitations of the EPA 600 / R93 / 116 method, nonfriable organically bound materials (NOBs) such as vinyl floor tiles can be difficult to analyze via polarized light microscopy (PLM). EPA recommends that all NOBs analyzed by PLM, and found not to contain asbestos, be further analyzed by Transmission Electron Microscopy (TEM). Please note that PLM analysis of dust and soil samples for asbestos is not covered under NVLAP accreditation. Estimated measurement of uncertainty is available on request.

Eurofins Built Environment Testing East, LLC makes no warranty representation regarding the accuracy of client submitted information in preparing and presenting analytical results. Interpretation of the analytical results is the sole responsibility of the client. This report relates only to the samples tested or analyzed and may not be reproduced, except in full, without written approval by Eurofins Built Environment Testing East, LLC. Samples were received in acceptable condition unless otherwise noted. This report may not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. Government.

Information provided by customer includes customer sample ID and sample description.


Raegan Brown
Analyst

DATA QA:

Madelyn Schmidt
4/15/2026

APPROVED BY:

Kamila Reichert,
Laboratory Director



CHAIN OF CUSTODY

7/11/2014

2750 Pleasant Rd. Suite 100A Fort Mill, SC 29504
 Tel: 803-539-5145 Fax: 803-539-5147

ECEI Lab Code: _____
 ECEI Lab ID Range: _____

COMPANY INFORMATION		PROJECT INFORMATION	
ECEI CLIENT #		ASB Contact	
Company		Email / Tel	
Address		Project Name	536 Landon St
City/State/Zip		Project ID#	Reference
Billing Email		PO #	
Tel		State of sample origin	

ECEI Standard Form ECF 101 03/04

IF TAT IS NOT MARKED STANDARD 3 DAY TAT APPLIES

ASBESTOS	METHOD	TURN AROUND TIME					
		4 HR	8 HR	1 DAY	2 DAY	3 DAY	5 DAY
PLM BLK	EPA 8200-R-01116	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PLM POINT COUNT 1000	EPA 8200-R-03116	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PLM POINT COUNT 1000	EPA 8200-R-03116	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PLM QUA & POINT COUNT	EPA 8200-R-03116	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PLM BLK	24HR 415	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PLM AIR	NIOSH 1400	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM AIR	EPA 8470A	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM AIR	NIOSH 7400	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM AIR (PCMT)	ISO 17013	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM AIR	ASTM E2811-10	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM BLK	OSHA 1910.101 EPA 8200-R-03116 24 HR 415 24 HR	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM SWL	ASTM E2811-10	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM VERMICULITE	OSHA 1910.101 EPA 8200-R-03116	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM QUALITATIVE	IN HOUSE METHOD	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
OTHER		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

*Blank should be used for all other samples not on this list

REMARKS / SPECIAL INSTRUCTIONS

Multiplex (Coversheet) attached to this form

Accept Samples
 Reject Samples

Regulated By:	Date/Time	Received By:	Date/Time
<i>[Signature]</i>	<i>[Date/Time]</i>	<i>[Signature]</i>	4/14/2014 9:29 AM

By submitting samples, you are agreeing to ECEI's Terms and Conditions.
 Samples will be disposed of 30 days after analysis.



SAMPLING FORM

COMPANY CONTACT INFORMATION

Company:	1111111111	Site Contact:	111111
Project Name:	555 London St		
Project ID#:	11111111	Site:	1111111111

SAMPLE ID#	DESCRIPTION / LOCATION	VOLUME / AREA	TEST	
			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
1			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
2			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
3			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
4			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
5			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
6			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
7			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
8			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
9			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
10			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
11			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
12			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
13			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
14			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
15			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
16			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
17			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
18			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
19			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
20			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
21			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
22			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
23			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
24			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
25			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
26			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
27			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
28			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
29			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
30			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
31			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
32			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
33			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
34			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
35			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
36			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
37			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
38			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
39			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>
40			PLM <input type="checkbox"/>	TEM <input type="checkbox"/>



Built Environment Testing

April 16, 2026

Enga Hair
ECH Consultants
1823 Trade Street
Florence, SC 29501

CLIENT PROJECT: Florence , 556 Lawson St
LAB CODE: 741666-2

Dear Enga,

Enclosed are asbestos analysis results for TEM bulk samples received at our laboratory on 04/14/26. The samples were analyzed for asbestos using transmission electron microscopy (TEM) per Chatfield/EPA 600/R-93/116 Sec. 2.5.5.1 method.

Sample results containing >1% asbestos are considered asbestos-containing materials (ACMs) per the EPA regulatory requirements. The detection limit for the TEM Chatfield/EPA 600/R-93/116 Sec. 2.5.5.1 method is <1% depending on the processed weight and constituents of the sample.

Thank you for your business and we look forward to continuing good relations.

Kind Regards,

A handwritten signature in black ink that reads "Kamila Reichert".

Kamila Reichert,
Laboratory Director

NVLAP 600323-0



| Built Environment Testing

ASBESTOS ANALYTICAL REPORT
By: Transmission Electron Microscopy

Prepared for

ECH Consultants

CLIENT PROJECT:	Florence , 556 Lawson St
LAB CODE:	741666-2
TEST METHOD:	Bulk Chatfield EPA 600 / R93 / 116 Sec. 2.5.5.1
REPORT DATE:	04/16/26



Built Environment Testing

ASBESTOS BULK ANALYSIS

By: Transmission Electron Microscopy

Client: ECH Consultants
1823 Trade Street
Florence, SC 29501

Lab Code: 741666-2
Date Received: 04/14/26
Date Analyzed: 04/16/26
Date Reported: 04/16/26

Project: Florence , 556 Lawson St

Method: TEM BULK CHATFIELD / EPA 600 / R93 / 116 Sec. 2.5.5.1

Client ID	Material	Sample	Organic	Acid Soluble	Acid Insoluble	ASBESTOS
Lab ID	Description	Weight (g)	Material (%)	Material (%)	Material (%)	%
9 4334330	White glazing	0.43	6.63	90.24	3.13	None Detected
12 4334331	Black shingle	0.3	42.46	35.69	21.85	None Detected



Built Environment Testing

LEGEND: None

METHOD: Bulk Chatfield EPA 600 / R93 / 116 Sec. 2.5.5.1

LIMIT OF DETECTION: Varies with the weight and constituents of the sample (<1%)

REGULATORY LIMIT: 1%

Eurofins Built Environment Testing East, LLC makes no warranty representation regarding the accuracy of client submitted information in preparing and presenting analytical results. Interpretation of the analytical results is the sole responsibility of the client. This report relates only to the samples tested or analyzed and may not be reproduced, except in full, without written approval by Eurofins Built Environment Testing East, LLC. Estimated measurement of uncertainty is available on request. Samples were received in acceptable condition unless otherwise noted.

Information provided by customer includes customer sample ID, location, volume and area as well as date and time of sampling. Eurofins Built Environment Testing East, LLC recommends between 0.500 and 0.200 grams of sample material. Any weight below 0.100 grams is considered below protocol guidelines.

Raegan Brown
Analyst

DATA QA:

Madelyn Schmidt
4/16/2026

APPROVED BY:

Kamila Reichert,
Laboratory Director



Built Environment Testing

RES Job #: 741666


SUBMITTED BY		INVOICE TO		SERIES	
Company: ECH Consultants		Company: ECH Consultants		-1 PLM Priority	
Address: 1823 Trade Street		Address: 1823 Trade Street			
Florence, SC 29501		Florence, SC 29501			
Project Number and/or P.O. #: Florence		Project Zn Code			
Project Description/Location: 556 Lawson St		Final Data Deliverable Email Address: eng@echconsultants.com (+ 1 ADDNL CONTACTS)			
		Contact: Enga Hair			
		Phone: (803) 807-6488			
		Fax:			
		Cell: (803) 807-6488			

ASBESTOS LABORATORY		REQUESTED ANALYSIS		VALID MATRIX CODES		LAB NOTES	
PLM/PCM/TEM/NYS	DTL RUSH	PRIORITY	STANDARD	ASBESTOS	CHEMISTRY	MICROBIOLOGY	ICO
CHEMISTRY LABORATORY							
Dust	RUSH PRIORITY STANDARD						
Metals	RUSH PRIORITY STANDARD						
Organics*	SAME DAY RUSH PRIORITY STANDARD						
MICROBIOLOGY LABORATORY							
Viable Analysis**	PRIORITY STANDARD						
Medical Device Analysis	RUSH STANDARD						
Mold Analysis	RUSH PRIORITY STANDARD						
Turnaround times establish a laboratory priority, subject to laboratory volume and are not guaranteed. Additional fees apply for afterhours, weekends and holidays.							
Special Instructions: SC samples, SC 1-day TAT TEM, Stop positives. Please see COC							
(Sample IDs must be unique)							
Client Sample ID Number							
1 1				X			
2 2				X			
3 3				X			
4 4				X			
5 5				X			
6 6				X			
7 7				X			
8 8				X			
9 9				X			
10 10				X			
11 11				X			
12 12				X			

Relinquished By: *Candice Wilkins* Date/Time: 04/14/2026 9:29:05 Sample Condition: **Acceptable**

Received By: *Candice Wilkins* Date/Time: 04/14/2026 11:40:19 Carrier: **Fed-Ex**

9/19/4811413 730 SE Maynard Rd, Cary, NC 27511 Page 1 of 1
 https://www.eurofins.com/builtenv



CHAIN OF CUSTODY

7/1/2014

2750 Pleasant Rd. Suite 100A Fort Mill, SC 29505
 Tel: 803-539-5145 Fax: 803-539-5147

ECFI Lab Code: _____
 ECFI Lab ID Range: _____

COMPANY INFORMATION		PROJECT INFORMATION	
ECFI CLIENT #:		Job Contact:	
Company:		Email To:	
Address:		Project Name:	556 Landon St
City/State/Zip:		Project ID#:	Reference
Phone E-mail:		PO #:	
Fax:		State of sample origin:	

IF TAT IS NOT MARKED STANDARD 3 DAY TAT APPLIES

ASBESTOS	METHOD	TURN AROUND TIME					
		4 HR	8 HR	1 DAY	2 DAY	3 DAY	5 DAY
PLM IIR	EPA 600/8-01-116	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PLM POINT COUNT 1000	EPA 600/8-01-116	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PLM POINT COUNT 100	EPA 600/8-01-116	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PLM GRAB & POINT COUNT	EPA 600/8-01-116	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PLM BLK	2400-435	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM AIR	NIOSH 1400	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM AIR	EPA 4018A	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM AIR	NIOSH 1400	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM AIR POINT	ISO 17012	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM AIR	ASTM E29115	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM BLK	2400-435 EPA 600/8-01-116	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM SOL	ASTM E29115	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM VERMICULITE	2400-435 (MATERIAL)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM QUALITATIVE	2400-435 METHOD	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
OTHER		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

REMARKS / SPECIAL INSTRUCTIONS

3 samples from Conference room at 556 Landon St. 11/11/2014

Accept Samples
 Reject Samples

Relinquished By:	Date/Time	Received By:	Date/Time
[Signature]	11/11/2014	[Signature]	4/11/2014 9:29 AM





SAMPLING FORM

COMPANY CONTACT INFORMATION


Company:	123456789	Site Contact:	123456
Plant Name:	567890123		
Project ID:	456789	Site:	123456789

SAMPLE ID	DESCRIPTION / LOCATION	VOLUME / AREA	TEST	
			PLM	TEM
1			<input type="checkbox"/>	<input type="checkbox"/>
2			<input type="checkbox"/>	<input type="checkbox"/>
3			<input type="checkbox"/>	<input type="checkbox"/>
4			<input type="checkbox"/>	<input type="checkbox"/>
5			<input type="checkbox"/>	<input type="checkbox"/>
6			<input type="checkbox"/>	<input type="checkbox"/>
7			<input type="checkbox"/>	<input type="checkbox"/>
8			<input type="checkbox"/>	<input type="checkbox"/>
9			<input type="checkbox"/>	<input type="checkbox"/>
10			<input type="checkbox"/>	<input type="checkbox"/>
11			<input type="checkbox"/>	<input type="checkbox"/>
12			<input type="checkbox"/>	<input type="checkbox"/>
13			<input type="checkbox"/>	<input type="checkbox"/>
14			<input type="checkbox"/>	<input type="checkbox"/>
15			<input type="checkbox"/>	<input type="checkbox"/>
16			<input type="checkbox"/>	<input type="checkbox"/>
17			<input type="checkbox"/>	<input type="checkbox"/>
18			<input type="checkbox"/>	<input type="checkbox"/>
19			<input type="checkbox"/>	<input type="checkbox"/>
20			<input type="checkbox"/>	<input type="checkbox"/>
21			<input type="checkbox"/>	<input type="checkbox"/>
22			<input type="checkbox"/>	<input type="checkbox"/>
23			<input type="checkbox"/>	<input type="checkbox"/>
24			<input type="checkbox"/>	<input type="checkbox"/>
25			<input type="checkbox"/>	<input type="checkbox"/>
26			<input type="checkbox"/>	<input type="checkbox"/>
27			<input type="checkbox"/>	<input type="checkbox"/>
28			<input type="checkbox"/>	<input type="checkbox"/>
29			<input type="checkbox"/>	<input type="checkbox"/>
30			<input type="checkbox"/>	<input type="checkbox"/>
31			<input type="checkbox"/>	<input type="checkbox"/>
32			<input type="checkbox"/>	<input type="checkbox"/>
33			<input type="checkbox"/>	<input type="checkbox"/>
34			<input type="checkbox"/>	<input type="checkbox"/>
35			<input type="checkbox"/>	<input type="checkbox"/>
36			<input type="checkbox"/>	<input type="checkbox"/>
37			<input type="checkbox"/>	<input type="checkbox"/>
38			<input type="checkbox"/>	<input type="checkbox"/>
39			<input type="checkbox"/>	<input type="checkbox"/>
40			<input type="checkbox"/>	<input type="checkbox"/>
41			<input type="checkbox"/>	<input type="checkbox"/>
42			<input type="checkbox"/>	<input type="checkbox"/>
43			<input type="checkbox"/>	<input type="checkbox"/>
44			<input type="checkbox"/>	<input type="checkbox"/>
45			<input type="checkbox"/>	<input type="checkbox"/>
46			<input type="checkbox"/>	<input type="checkbox"/>
47			<input type="checkbox"/>	<input type="checkbox"/>
48			<input type="checkbox"/>	<input type="checkbox"/>
49			<input type="checkbox"/>	<input type="checkbox"/>
50			<input type="checkbox"/>	<input type="checkbox"/>

SCDES INSPECTOR LICENSE

 **SCDES ISSUED** 
Arrested B Card

Enga Hair

	AIRSAMPLER	AS-00538	Expiration Date:
	CONSULTBI	BI-01591	09/21/26
	CONSULTPD	PD-00184	09/22/26
	SUPERAHERA	SA-02878	03/03/27
			09/21/26